



# pennsylvania

DEPARTMENT OF ENVIRONMENTAL PROTECTION  
NORTHCENTRAL REGIONAL OFFICE

September 21, 2011

**CERTIFIED MAIL NO. 7010 2780 0001 8652 0186**

Andrew Chichura  
9345 State Route 106  
Kingsley, PA 18826

Re: Act 223, Section 208 Determination  
Complaint No. 282431  
Lenox Township, Susquehanna County

Dear Mr. Chichura:

The Department has investigated the possible degradation of your water supply well located at 9345 State Route 106, Lenox Township, Susquehanna County in response to an 8/16/2011 complaint that recent gas well drilling activities may have affected your water well. On 8/16/2011 and 8/18/2011, the Department collected samples from your water supply. The samples were submitted to the Department's laboratory in Harrisburg for analysis. The analytical reports for the samples are included, as well as documents that will assist you with interpreting the sample results. The sample results showed methane was present at 49.20 milligrams per Liter (mg/L) on 8/16/2011 and 57.60 mg/L on 8/18/2011 in your water supply. Combustible gas was also detected in the headspace of your water well. The Department investigation indicates that gas well drilling has impacted your water supply.

Methane is the predominant component of natural gas. Federal water standard limitations have not been established for methane gas. The level of concern begins above 28 mg/L methane, which is referred to as the saturation level. At this level, under normal atmospheric pressure, the water cannot hold additional methane in solution. This may allow the gas to come out of the water and concentrate in the air space of your home or building. There is a physical danger of fire or explosion due to the migration of natural gas into water wells or through soils into dwellings where it could be ignited by sources that are present in most homes/buildings. Natural gas can also cause a threat of asphyxiation, although this is extremely rare.

When the Department is made aware of methane levels greater than 7 mg/L, we notify the water supply owner of the hazards associated with methane in their water supply. Please be aware however, that the methane levels can fluctuate. This means that even with a relatively low level of methane, you should be vigilant of changes in your water that could indicate an increase in methane concentration.

208 West Third Street | Suite 101 | Williamsport, PA 17701-6448

570.327.3636 | Fax 570.327.3565

Printed on Recycled

[www.depweb.state.pa.us](http://www.depweb.state.pa.us)

Scanned by CamScanner

Mr. Andrew Chichura


-2-

9/21/2011

It is the Department's recommendation that all water wells should be equipped with a working vent. This will help alleviate the possibility of concentrating these gases in areas where ignition would pose a threat to life or property. Please note that it is not possible to completely eliminate the hazards of having natural gas in your water supply by simply venting your well.

The Department is continuing to work to permanently resolve this issue. Should you have any questions concerning this matter, please feel free to contact Eric Rooney at 570-346-5543.

Sincerely,



Jennifer W. Means  
Environmental Program Manager  
Oil and Gas Management

Enclosures:

Laboratory Analytical Results  
"How to Interpret A Water Analysis Report"

cc:

Jennifer Means  
Marc B. Cooley  
William J. Kosmer, P.G.  
Eric Rooney  
Ryan Klemish  
Complaint File 282431  
Chichura File